

Report for:

Ted Gusick
Adaptive Environmental Colorado
741 Rider Ridge Dr
Longmont, CO 80504

Regarding: Project: COTG211101-1480-ASB; 1480 Golfcourse Rd
EML ID: 2775378

Approved by:

Dates of Analysis:
Asbestos PLM: 11-02-2021



Approved Signatory
Amber Rutter

Service SOPs: Asbestos PLM (EPA 40CFR App E to Sub E of Part 763 & EPA METHOD 600/R-93-116, SOP EM-AS-S-1267)
NVLAP Lab Code 500053-0

All samples were received in acceptable condition unless noted in the Report Comments portion in the body of the report. The results relate only to the samples as received and tested. The results include an inherent uncertainty of measurement associated with estimating percentages by polarized light microscopy. Measurement uncertainty data for sample results with >1% asbestos concentration can be provided when requested.

Eurofins EMLab P&K ("the Company") shall have no liability to the client or the client's customer with respect to decisions or recommendations made, actions taken or courses of conduct implemented by either the client or the client's customer as a result of or based upon the Test Results. In no event shall the Company be liable to the client with respect to the Test Results except for the Company's own willful misconduct or gross negligence nor shall the Company be liable for incidental or consequential damages or lost profits or revenues to the fullest extent such liability may be disclaimed by law, even if the Company has been advised of the possibility of such damages, lost profits or lost revenues. In no event shall the Company's liability with respect to the Test Results exceed the amount paid to the Company by the client therefor.

Client: Adaptive Environmental Colorado
 C/O: Ted Gusick
 Re: COTG211101-1480-ASB; 1480 Golfcourse Rd

Date of Receipt: 11-02-2021
 Date of Report: 11-02-2021

ASBESTOS PLM REPORT

Total Samples Submitted:	20
Total Samples Analyzed:	20
Total Samples with Layer Asbestos Content > 1%:	0

Location: D-1, Front desk counter

Lab ID-Version‡: 13282040-1

Sample Layers	Asbestos Content
Red Countertop	ND
Yellow Mastic	ND
Composite Non-Asbestos Content:	60% Cellulose
Sample Composite Homogeneity:	Moderate

Location: D-2, Front desk counter

Lab ID-Version‡: 13282041-1

Sample Layers	Asbestos Content
Red Countertop	ND
Yellow Mastic	ND
Composite Non-Asbestos Content:	60% Cellulose
Sample Composite Homogeneity:	Moderate

Location: D-3, Front desk counter

Lab ID-Version‡: 13282042-1

Sample Layers	Asbestos Content
Red Countertop	ND
Yellow Mastic	ND
Composite Non-Asbestos Content:	60% Cellulose
Sample Composite Homogeneity:	Moderate

Location: BC-1, Bar counter

Lab ID-Version‡: 13282043-1

Sample Layers	Asbestos Content
Tan Floor Tile	ND
Yellow Mastic	ND
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Adaptive Environmental Colorado
 C/O: Ted Gusick
 Re: COTG211101-1480-ASB; 1480 Golfcourse Rd

Date of Receipt: 11-02-2021
 Date of Report: 11-02-2021

ASBESTOS PLM REPORT

Location: BC-2, Bar counter

Lab ID-Version‡: 13282044-1

Sample Layers	Asbestos Content
Tan Floor Tile	ND
Yellow Mastic	ND
Sample Composite Homogeneity: Moderate	

Location: BC-3, Bar counter

Lab ID-Version‡: 13282045-1

Sample Layers	Asbestos Content
Tan Floor Tile	ND
Yellow Mastic	ND
Sample Composite Homogeneity: Moderate	

Location: KH-1, Kitchen hall

Lab ID-Version‡: 13282046-1

Sample Layers	Asbestos Content
Off-White Sheet Flooring	ND
Semi-Transparent Mastic	ND
Sample Composite Homogeneity: Moderate	

Location: KH-2, Kitchen hall

Lab ID-Version‡: 13282047-1

Sample Layers	Asbestos Content
Off-White Sheet Flooring	ND
Semi-Transparent Mastic	ND
Sample Composite Homogeneity: Moderate	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Adaptive Environmental Colorado
 C/O: Ted Gusick
 Re: COTG211101-1480-ASB; 1480 Golfcourse Rd

Date of Receipt: 11-02-2021
 Date of Report: 11-02-2021

ASBESTOS PLM REPORT

Location: KH-3, Kitchen hall

Lab ID-Version‡: 13282048-1

Sample Layers	Asbestos Content
Off-White Sheet Flooring	ND
Semi-Transparent Mastic	ND
Sample Composite Homogeneity: Moderate	

Location: F-1, Kitchen office vinyl

Lab ID-Version‡: 13282049-1

Sample Layers	Asbestos Content
Off-White Sheet Flooring	ND
Semi-Transparent Mastic	ND
Sample Composite Homogeneity: Moderate	

Location: F-2, Kitchen office vinyl

Lab ID-Version‡: 13282050-1

Sample Layers	Asbestos Content
Off-White Sheet Flooring	ND
Semi-Transparent Mastic	ND
Sample Composite Homogeneity: Moderate	

Location: F-3, Kitchen office vinyl

Lab ID-Version‡: 13282051-1

Sample Layers	Asbestos Content
Off-White Sheet Flooring	ND
Semi-Transparent Mastic	ND
Sample Composite Homogeneity: Moderate	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Adaptive Environmental Colorado
 C/O: Ted Gusick
 Re: COTG211101-1480-ASB; 1480 Golfcourse Rd

Date of Receipt: 11-02-2021
 Date of Report: 11-02-2021

ASBESTOS PLM REPORT

Location: F-4, Kitchen office vinyl

Lab ID-Version‡: 13282052-1

Sample Layers	Asbestos Content
Off-White Sheet Flooring	ND
Semi-Transparent Mastic	ND
Sample Composite Homogeneity: Moderate	

Location: F-5, Kitchen office vinyl

Lab ID-Version‡: 13282053-1

Sample Layers	Asbestos Content
Off-White Sheet Flooring	ND
Semi-Transparent Mastic	ND
Sample Composite Homogeneity: Moderate	

Location: F-6, Kitchen office vinyl

Lab ID-Version‡: 13282054-1

Sample Layers	Asbestos Content
Brown Sheet Flooring	ND
Semi-Transparent Mastic	ND
Sample Composite Homogeneity: Moderate	

Location: C-1, Entry

Lab ID-Version‡: 13282055-1

Sample Layers	Asbestos Content
Green Carpet	ND
Yellow Mastic	ND
Composite Non-Asbestos Content: 60% Synthetic Fibers	
Sample Composite Homogeneity: Moderate	

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: Adaptive Environmental Colorado
 C/O: Ted Gusick
 Re: COTG211101-1480-ASB; 1480 Golfcourse Rd

Date of Receipt: 11-02-2021
 Date of Report: 11-02-2021

ASBESTOS PLM REPORT

Location: C-2, Entry

Lab ID-Version‡: 13282056-1

Sample Layers	Asbestos Content
Green Carpet	ND
Yellow Mastic	ND
Composite Non-Asbestos Content:	60% Synthetic Fibers
Sample Composite Homogeneity:	Moderate

Location: C-3, Bar

Lab ID-Version‡: 13282057-1

Sample Layers	Asbestos Content
Green Carpet	ND
Yellow Mastic	ND
White Compound	ND
Composite Non-Asbestos Content:	60% Synthetic Fibers
Sample Composite Homogeneity:	Poor

Location: C-4, Lower level

Lab ID-Version‡: 13282058-1

Sample Layers	Asbestos Content
Green Carpet	ND
Yellow Mastic	ND
Composite Non-Asbestos Content:	60% Synthetic Fibers
Sample Composite Homogeneity:	Moderate

Location: C-5, Lower level

Lab ID-Version‡: 13282059-1

Sample Layers	Asbestos Content
Green Carpet	ND
Yellow Mastic	ND
Composite Non-Asbestos Content:	60% Synthetic Fibers
Sample Composite Homogeneity:	Moderate

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. Eurofins EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".